

State Permit Attached

TOWN OF ESSEX
CERTIFICATE OF OCCUPANCY APPLICATION

DATE OF REQUEST: _____ FEE: \$85.00 (includes recording)

MAP/PARCEL/LOT: 2/052/017/001

NO. 2012-150

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

This request is for use only of existing land or buildings.

This request is for new construction or rehabilitated or altered structure which was done under authority of zoning permit # 2012-150

issued to Mountaha Handy Trust (Dunkin Donuts) OR 9-10-12

Premises are at 136 Jericho Rd

Water service installation inspected and approved by Existing

Driveway location inspected and approved by Existing

Sanitary sewer connection or septic system inspected and approved by:

Name: _____ Date: Existing

Construction was begun _____, 20____ and completed _____, 20____

Approval granted by P.C. or Z.B.A. on Feb 27, 2012. (PC# 2012-3)

Use of premises intended Commercial drive thru window (type of use)

Applicant's Signature: [Signature] Telephone: _____ Cell: _____

By issuance of this Occupancy Permit, the Town of Essex Zoning Administrator hereby acknowledges that the use and/or building construction is in complete conformity with the Zoning Regulations, unless otherwise noted. Field measurements and similar dimensions for setbacks are based in part on evidence supplied by owner. The Town of Essex is not liable for errors or mistakes when it is found that information submitted by the applicant is erroneous or inaccurate.

Certificate of Occupancy has been approved with _____ without _____ conditions. If with conditions, see attachment outlining same.

Certificate of Occupancy denied _____. Please see attachment with reasons for denial.

7-5-13
Date

[Signature]
Zoning Administrator



Vermont Department of Public Safety
DIVISION OF FIRE SAFETY
 Office of the State Fire Marshal, State Fire Academy and State Haz-Mat Team
 firesafety.vermont.gov



Barre Regional Office
 1311 U.S. Route 302 - Berlin, Suite 500
 Barre, VT 05641
 [phone] 802-479-4434
 [fax] 802-479-4446

Rutland Regional Office
 56 Howe Street, Building A, Suite 200
 Rutland, VT 05701-3449
 [phone] 802-786-5867
 [fax] 802-786-5872

Williston Regional Office
 372 Hurricane Lane, Suite 102
 Williston, VT 05495-2080
 [phone] 802-879-2300
 [fax] 802-879-2312

Springfield Regional Office
 100 Mineral Street, Suite 307
 Springfield, VT 05156-3168
 [phone] 802-885-8883
 [fax] 802-885-8885

FIRE INSPECTION RESULTS

Site Id: 35579

Structure Information

Name: SIMONS CONVENIENCE STORE / DUNKIN DONUTS
 Address: 134 JERICO ROAD - ROUTE 15
 Structure Id: 35579 ESSEX, VT 05452

Owner Information

Owner: SALAMIN HANDY (N 24705)
 Phone: 863-2984
 Address: 1333 WILLISTON RD
 S BURLINGTON, VT 05403

Building Description

Risk Index: L3	Smoke Det:	Occupants: 1	Units:
Const Type: 5B	CO Detect:	Stand Pipe:	Floors: 1
Occ Type: M	Fire Alarm:	Sprinkler:	Sq Feet: 3600
Heating: Gas Fired Hot Air			

Project Description

Name: Addition/Renovation - August 2012
 Type: Building Project Received: 08/29/2012 Workitem Id: 338336

Inspection Detail

Insp Date: 06/05/2013 Insp Type: Initial Violations: 2
 Comply By: Occ Granted: Yes Hazard Index: Level 2
 Inspector: TODD COSGROVE (S 91232)

Violations and Notes

This is a final inspection of the addition to the store of a new Dunkin Doughnuts Drive Thru.

Two minor Violations were noted that the time of inspection, they are;

- 1) cover missing from junction box on wall to right of drive thru window, replace the cover.
- 2) computer in Dunkin Doughnuts storage area, is placed directly in front of two electrical panels. Please move this set up, so there is 36 inches of clearance in front of the panels.
- 3) need to have additional outlets added to the area, to remove the three connected surge protected power strips used for power to the computer and other hardware.

A Final Electrical inspection needs to be scheduled with our Electrical Inspector and the Electrician that performed the work, so the Electrical Permit can be closed out.

I will include a Compliance Certificate for you to fill in, sign and date, then return to me with proof (invoice or photo), showing the Violations have been corrected.

I have set the Hazard Index at Level 2 and the Occupancy Status at Yes.

This Report is Closed.