

TOWN OF ESSEX CERTIFICATE OF OCCUPANCY APPLICATION

DATE OF REQUEST: 4/6/12 FEE: \$85.00 pd. (includes recording)
MAP/PARCEL/LOT: 2-091-006-000 NO. 2012-4

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

- This request is for use only of existing land or buildings.
- This request is for new construction or rehabilitated or altered structure which was done under authority of zoning permit # 2012-04

issued to Summerville LLC on 2/9/12

Premises are at 8 Essex Way, Essex Junction, VT 05452

Water service installation inspected and approved by Public T of Essex

Driveway location inspected and approved by T of Essex

Sanitary sewer connection or septic system inspected and approved by:

Name: Public supply ^{Existing} Date: _____

Construction was begun 2/9/12, 20 12 and completed 3/30, 20 12

Approval granted by P.C. or Z.B.A. K on 2/9, 20 12.

Use of premises intended Business office (Perdue Agribusiness Inc)
(type of use)

Applicant's Signature: John M. Summerville Telephone: ⁸⁰² 8791233 Cell: 7340994

By issuance of this Occupancy Permit, the Town of Essex Zoning Administrator hereby acknowledges that the use and/or building construction is in complete conformity with the Zoning Regulations, unless otherwise noted. Field measurements and similar dimensions for setbacks are based in part on evidence supplied by owner. The Town of Essex is not liable for errors or mistakes when it is found that information submitted by the applicant is erroneous or inaccurate.

Certificate of Occupancy has been approved with _____ without conditions.
If with conditions, see attachment outlining same.

Certificate of Occupancy denied _____ . Please see attachment with reasons for denial.

Date 4/6/12 Shawn L. Kelly
Zoning Administrator



Vermont Department of Public Safety
DIVISION OF FIRE SAFETY



Office of the State Fire Marshal, State Fire Academy and State Haz-Mat Team
 firesafety.vermont.gov

Barre Regional Office
 1311 U.S. Route 302 - Berlin, Suite 500
 Barre, VT 05641
 [phone] 802-479-4434
 [fax] 802-479-4446

Rutland Regional Office
 56 Howe Street, Building A, Suite 200
 Rutland, VT 05701-3449
 [phone] 802-786-5867
 [fax] 802-786-5872

Williston Regional Office
 372 Hurricane Lane, Suite 102
 Williston, VT 05495-2080
 [phone] 802-879-2300
 [fax] 802-879-2312

Springfield Regional Office
 100 Mineral Street, Suite 307
 Springfield, VT 05156-3168
 [phone] 802-885-8883
 [fax] 802-885-8885

FIRE INSPECTION RESULTS

Site Id: 29929

Structure Information

Name: ALDERBROOK OFFICE CONDOMINIUMS (FMR SUMMERSVILLE) Address: 8 ESSEX WAY
 Structure Id: 29929 ESSEX, VT 05452

Owner Information

Owner: JOHN DR (DMD) SUMMERSVILLE (N 33338) Address: 16 LONDONDERRY LANE
 ESSEX JCT, VT 05452

Building Description

Risk Index: L3	Smoke Det:	Occupants:	Units: 4
Const Type: 5B	CO Detect:	Stand Pipe:	Floors: 2
Occ Type: AB	Fire Alarm: Automatic	Sprinkler: Limited	Sq Feet: 5944
Heating: Gas Fired Hot Air			

Project Description

Name: LANG FARM CENTER (RENO UNITS 2D/104 DEC 2011)
 Type: Building Project Received: 01/10/2012 Workitem Id: 327838

Inspection Detail

Insp Date: 04/01/2012 Insp Type: Occupancy Violations:
 Inspector: CHRIS A BOYD (S 58514) Referred To: JOHN DR (DMD) SUMMERSVILLE (N 33338)
 Copy To: Essex Town Fire Department

Violations and Notes

This is a final inspection for Suite 203. All fire alarm devices are in place and were pre-tested by the TQP prior to final inspection. Keys for the Fire Department key box will be provided and the suite number posted upon issuance of the Town of Essex CO.