

TOWN OF ESSEX

2072006000 APPLICATION FOR CERTIFICATE OF OCCUPANCY

No. 144-82

2-15-83 19

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

This request is for use only of existing land or buildings.

This request is for new construction or rehabilitated or altered structure which was done under authority of building permit # 144-82

issued Oct 7 1982 to Mili Bride Inc.

Premises are at 26 Thompson Drive

Driveway location inspected and approved by R. Coltran

Water service installation (if necessary) inspected and approved by R. Stafford

Sanitary sewer connection or septic system inspected and approved Michael C. Weisel P.E. 1983 by 2-25-83 (Signature)

Construction was begun October 25 1982 and completed substantially March 1 1983.

Actual cost of construction \$ 1,500,000.

Use of premises intended Manufacturing and office space

Land was conveyed by \_\_\_\_\_ and is recorded in Vol. \_\_\_\_\_ page \_\_\_\_\_ of the Town of Essex Land Records by \_\_\_\_\_ grantor to \_\_\_\_\_ grantee.

Date Feb. 15, 1983 Applicant's Signature [Signature]

Certificate of Occupancy is herewith (approved) (denied) and in the event of denial the reasons therefore are given in writing according to law, a copy of which is appended hereto.

~~Conditional Certificate of Occupancy See Attachment~~

Date 1/18/06 [Signature]  
Zoning Administrator  
Town of Essex, Vermont

This will verify that all of the attached conditions have been satisfactorily resolved. [Signature] Z.A. 1/18/06



( DONALD L. HAMLIN ( )  
CONSULTING ENGINEERS, INC.  
ENGINEERS AND LAND SURVEYORS  
ESSEX JUNCTION, VERMONT 05452

COLCHESTER ROAD  
P.O. BOX 9

February 25, 1983

Tel. 878-3956  
878-5123

RECEIVED  
TOWN OF ESSEX  
Zoning Office

*Dma*  
FEB 28 1983

Mr. Ernest Christianson  
State of Vermont  
Agency of Environmental Conservation  
111 West Street  
Essex Junction, Vermont 05452

Re: Sewage Disposal Certification  
Mili Bride, Essex, Vermont

Dear Ernie:

This is to certify that the sewage disposal system at the Mili Bride project in the Saxon Hill Industrial Park has been completed substantially in accordance with the approved plans. The approved Flygt pumps have been replaced with Peabody-Barnes pumps having similar pumping characteristics, however all other components of the system are as shown.

The following site inspections were made by this office:

1. November 4, 1982 - Inspection of septic and dosing tank leakage. Dosing tank approved with no leakage. Septic tank not approved with 6" drop in 24 hours.
2. November 9, 1982 - Septic tank re-tested and approved with no leakage. Pressure and leakage test performed on force main. Approved with no leakage.
3. November 15, 1982 - Inspection of partially completed disposal bed. Stone depth, number of distribution pipes, level of pipes and overall quality of work were acceptable.
4. February 25, 1983 - Inspection of pump and control installation as well as pump operation. All components were installed and operating as designed.

If there are any questions, please feel free to call.

Sincerely,

Michael C. Weisel, P.E.

MCW:lgw

cc: Alex Rose; Town of Essex

WATER SUPPLY AND DISTRIBUTION  
WASTE WATER COLLECTION AND TREATMENT  
STREETS AND HIGHWAYS  
AIRPORTS

SUBDIVISIONS  
SKI LIFTS  
RECREATION AND INDUSTRIAL PLANNING  
SOIL BORINGS

LABORATORY ANALYSIS  
(WATER AND WASTE WATER)  
LAND SURVEYING  
SOLID WASTE MANAGEMENT