

Appeal Period Expires 1/5/22  
 Zoning District AR

**Town of Essex, Vermont**  
**Application for Zoning Permit**  
 (Building Permit)

Application Date 1/1  
 Permit Number 2021-218

- Contact State Permit Specialist Jeff McMahon (477-2241) to check for state permitting and/or setbacks.
- Post permit card visible to the road immediately as Permit is appealable within 15 days of issuance.
- Call the Zoning Administrator at 878-1343 to schedule a Certificate of Occupancy inspection if indicated below as required.
- Call the Assessor at 878-1345 to schedule a re-assessment upon completion of work.

Signed: \_\_\_\_\_

**A** Parcel Account Numb. (Map-Parcel-Lot) 2-105-107-008  
 Property Address: 2 Deer Crossing Lane  
 Owner: Eric Sven EKLOF JR + IRMA EKLOF  
 Owner Address: 2 Deer Crossing Lane  
 Owner Phone: (work) \_\_\_\_\_ (home) \_\_\_\_\_  
 (cell) 802-238-5102 (Email) Sveneklof@yahoo.com  
 Tenants name: \_\_\_\_\_ Phone: \_\_\_\_\_  
 Cell: \_\_\_\_\_  
 Estimated Construction Dates: Start: 12/21 Completion: 12/21  
 Sq. Feet: 380 Estimated Cost (labor & materials): \$ 0

**G**

Check box(es) which describe proposed use or construction (circle choice in parenthesis).  
 N = New A = Addition R = Remodel

<i>Residential:</i>	N	A	R
Single Family	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Two-family (duplex)(other)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Multi-family	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Condominium / Townhouse	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mobile home	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Inclusions or Additions:</i>			
Garage (attached) (detached)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Porch (enclosed) (open)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Deck	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pool (in) (above) ground	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Shed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Barn (residential) (agriculture)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Non-residential:</i>			
Commercial / Industrial	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Stormwater:</i>			
Stormwater	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Erosion Control	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Other:</i>			
Change in use	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Miscellaneous	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Renewal	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**B** Sewage Disposal (Please attach Sewer or Septic Application).  
 Public  Septic  Connection Fee \$ 0 Date Paid: 1/1  
 Proposed New Bedrooms: 1 Existing Bedrooms 3  
WW-4-51022

**C** Water (Please attach Water Service Application).  
 Public  Well  Fee \$ \_\_\_\_\_ Date Paid: 1/1

**D** Driveway (Please attach copy of approved Curbcut / Utility Application).  
 Date of approval 1/1 existing

**E** Stormwater N/A  
 Project disturbs an area greater than or equal to 1 acre – Erosion Control Permit Required. Attach completed permit application.  
 Project creates new or expands existing impervious surface greater than or equal to 1/2 acre – Erosion Control Permit and Stormwater Management Permit required. Attach completed permit application.

**F** Diagram – Show a sketch of project on reverse of this application with property lines, building, and setbacks or attach separate sheet.

**G** \*Rever\*  
see other side  
 Signature of Tenant and Signature of Owner [Signature]

**Office Use Only**

Fees:	Type	Amount	Date Pd
Permit		\$ <u>75</u>	<u>1/1</u>
Recreation		\$ _____	
Recording		\$ <u>15</u>	<u>12/21/21</u>
Certificate of Occ		\$ _____	<u>1/1</u>
Other		\$ _____	<u>1/1</u>

**Building Permit**  
 Approved  Rejected  Date 12/21, 2021

Issued to: E + I EKLOF

Zoning Administrator: [Signature]

Notes: \_\_\_\_\_

C.O. Required Yes  No

**THIS PERMIT VALID FOR TWELVE (12) MONTHS FROM DATE OF ISSUE  
 RENEW FOR 1 YEAR (FREE) IF NOT EXPIRED**

F Diagram - Provide diagram here and include all setbacks

Vermont Waste Water Permit: WW4-5622

- Waste water disposal system converted to 4 bedroom
- The finished space above the 2 car garage will be converted to a bedroom. This finished space was completed in 2006 prior to our ownership. There was no cost for the bedroom. \*see 2006-33 ZP

**WASTEWATER SYSTEM AND POTABLE WATER SUPPLY PERMIT****LAWS/REGULATIONS INVOLVED**10 V.S.A. Chapter 64, Potable Water Supply and Wastewater System Permit  
Wastewater System and Potable Water Supply Rules, Effective April 12, 2019**Permittee(s): Eric S. Eklof, Jr.**  
**2 Deer Crossing Lane**  
**Essex Jct., VT 05452****Permit Number: WW-4-5622****Irma Eklof**  
**2 Deer Crossing Lane**  
**Essex Jct., VT 05452**

This permit affects the following property/properties in Essex, Vermont:

Lot	Parcel	SPAN	Acres	Book(s)/Page(s)#
8	2105107008	207-067-13533	0.83	Book:758 Page(s):608

This application, consisting of a replacement wastewater disposal system for an existing three (3) bedroom single family residence to be converted to a four (4) bedroom single family residence and eliminate the previously permitted designated replacement area on an existing 0.83-acre parcel utilizing an existing municipal water service connection located at 2 Deer Crossing Lane in Essex, Vermont, is hereby approved under the requirements of the regulations named above subject to the following conditions. Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

**1. GENERAL**

- 1.1 The permittee is responsible to record this permit in the Essex Land Records within 30 days of issuance of this permit and prior to the conveyance of any lot subject to the jurisdiction of this permit.
- 1.2 The permittee is responsible to record the design and installation certifications and other documents that are required to be filed under these Rules or under a permit condition in the Essex Land Records.
- 1.3 Each assign or successor in interest shall be shown a copy of the Wastewater System and Potable Water Supply Permit and the stamped plan(s) prior to the conveyance of a lot.
- 1.4 The wastewater system includes the use of an Innovative/Alternative treatment component. Each prospective owner of a lot that utilizes the Innovative/Alternative component shall be shown a copy of the **Innovative/Alternative System Approval letter #2013-02-R6 for the JET™ Wastewater Treatment System Series** for model **J750** prior to conveyance of the lot.
- 1.5 The owner of a lot with an Innovative/Alternative treatment system shall have a valid maintenance contract in force at all times with a vendor-trained and authorized licensed designer or service provider to conduct inspections and maintenance of the System.
- 1.6 By acceptance of this permit, the permittee agrees to allow representatives of the State of Vermont access to the property covered by the permit, at reasonable times, for the purpose of ascertaining compliance with the Vermont environmental and health statutes and regulations, and permit conditions.
- 1.7 This permit does not relieve the landowner from obtaining all other approvals and permits from other State Agencies or Departments, or local officials prior to construction.
- 1.8 All conditions set forth in **EC-4-1372** shall remain in effect except as amended or modified herein.



## 2. CONSTRUCTION

- 2.1 Construction shall be completed as shown on the plans and/or documents prepared by Willis Design Associates, Inc. (Justin Willis, Licensed Designer) with the stamped plans listed as follows:

Title	Sheet #	Plan Date	Revision
<i>Wastewater System Design</i>	1	7/16/21	8/10/21
<i>Wastewater System Design</i>	2	7/16/21	8/10/21

- 2.2 The landowner shall complete construction of the wastewater system approved by this permit **no later than December 1, 2021**. The landowner may request one extension of this deadline, provided the landowner makes the request in writing a week prior to the specified date, and shows good cause why construction cannot be completed by the stated date. If this condition is not met, this permit shall no longer remain effective for the purpose of authorizing construction of the replacement system and will require an application for an amendment.
- 2.3 The landowner is required to continue any measures necessary to prevent wastewater from surfacing on top of the ground, entering surface waters of the State, or backing up into the existing residence until such time as the approved wastewater system is constructed, activated, and all the conditions of this permit are satisfied.
- 2.4 Construction of wastewater systems or potable water supplies, or buildings or structures (as defined by the Wastewater System and Potable Water Supply Rules), or campgrounds, not depicted on the stamped plans, or identified in this permit, is not allowed without prior approval by the Drinking Water and Groundwater Protection Division.
- 2.5 No buildings, roads, water pipes, sewer services, earthwork, re-grading, excavation, or other construction that might interfere with the operation of the wastewater system or potable water supply are allowed on or near the site-specific wastewater system, wastewater replacement area, or potable water supply depicted on the stamped plans. Adherence to all isolation distances that are set forth in the Wastewater System and Potable Water Supply Rules is required.

## 3. INSPECTIONS

- 3.1 No permit issued by the Secretary shall be valid for a substantially completed potable water supply and wastewater system until the Secretary receives a signed and dated certification from a qualified Vermont Licensed Designer (or where allowed, the installer) on a Secretary-approved form that states:
- "I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and the wastewater system was installed in accordance with the permitted design and all permit conditions, was inspected, was properly tested, and has successfully met those performance tests."*
- or which satisfies the requirements of §1-311 of the referenced rules.
- 3.2 A vendor-approved service provider of the Innovative/Alternative treatment system shall provide the Drinking Water and Groundwater Protection Division a start-up report, certifying the Innovative/Alternative System was installed and is functioning in a manner that complies with the vendor requirements within 60 days of installation and usage.
- 3.3 A vendor-approved service provider shall conduct an inspection of the Innovative/Alternative treatment system every six months following installation and use of the treatment system for the initial two years. The inspection report shall be provided to the landowner and submitted to the Division within 60 days of when the inspection is conducted.
- 3.4 Following the initial two years of service, a vendor-approved service provider shall conduct an annual inspection of the Innovative/Alternative treatment system. The inspection report shall be submitted to the Division by December 31st of the year the inspection is conducted.
- 3.5 The Drinking Water and Groundwater Protection Division may require sampling of effluent from the Innovative/Alternative treatment system to confirm the filtrate effluent is being treated to reduce the BOD<sub>5</sub> to 30 mg/L or less and total suspended solids (TSS) to 30 mg/L or less.

3.6 The Innovative/Alternative treatment system shall function in accordance with the vendor requirement. The Drinking Water and Groundwater Protection Division shall be immediately notified if the treatment system is not functioning according to the vendor requirements, or the effluent quality does not comply with BOD<sub>5</sub> to 30 mg/L or less and total suspended solids (TSS) to 30 mg/L or less.

**4. DESIGN FLOW**

4.1 Lot use and design flows (gpd) shall correspond to the following:

Lot	Building	Building Use / Design Flow Basis	Wastewater	Water
8	Existing	3-Bedroom Single Family Residence to convert to a 4-Bedroom Single Family Residence (max. 8 people)	560	360

**5. WASTEWATER SYSTEM**


- 5.1 Prior to construction or site work, a designer shall flag the proposed leachfield, and the owner shall maintain the flags until commencement of construction of the system.
- 5.2 Should the wastewater system fail and not qualify as a minor repair or for an exemption, the landowner shall engage a qualified Licensed Designer to evaluate the cause of the failure and submit an application to the Drinking Water and Groundwater Protection Division, and obtain approval thereof, prior to correcting the failure.
- 5.3 This permit does not relieve the permittee of the obligations of Title 10, Chapter 48, Subchapter 4, for the protection of groundwater.

**6. POTABLE WATER SUPPLY**

- 6.1 This project is approved with an existing municipal water service connection.
- 6.2 This project is approved with an existing water service line. The Drinking Water and Groundwater Protection Division assumes no liability for the adequacy of this service line. Should the line fail and not qualify for the minor repair or replacement exemption, the landowner shall engage a Licensed Designer to evaluate the cause of the failure and to submit an amendment application to this office, and obtain approval thereof, prior to correcting the failure.

Peter Walke, Commissioner  
Department of Environmental Conservation

Dated August 11, 2021

By   
Allison Lowry, Environmental Analyst VI  
Essex Junction Regional Office  
Drinking Water and Groundwater Protection Division

Enclosure: I/A Approval Letter

cc: Willis Design Associates, Inc.  
Innovative/Alternative Manufacturer – Jet, Inc.

**WASTEWATER SYSTEM AND POTABLE WATER SUPPLY  
INNOVATIVE AND ALTERNATIVE (I/A) TECHNOLOGY  
GENERAL USE APPROVAL PERMIT****LAWS/REGULATIONS INVOLVED**10 V.S.A. Chapter 64, Potable Water Supply and Wastewater System Permit  
Wastewater System and Potable Water Supply Rules, Effective April 12, 2019**Permittee:** Jet Inc.  
750 Alpha Drive  
Cleveland, OH 44143  
(800) 321-6960  
www.jetincorp.com**Permit Number:** 2013-02-R6  
**Date Issued:** 05/20/2021  
**Date Expires:** 05/01/2023

This permit is for the following aerobic, fixed film media I/A technology models:

Product Name	Model Number(s)	Design Flow (gpd)
<b>J-1500 BAT Media Systems</b>	J-500	500
<b>J-1500 BAT Media Systems</b>	J-500-PLT	500
<b>J-1500 BAT Media Systems</b>	J-750	750
<b>J-1500 BAT Media Systems</b>	J-800-PLT	800
<b>J-1500 BAT Media Systems</b>	J-1000	1000
<b>J-1500 BAT Media Systems</b>	J-1250	1250
<b>J-1500 BAT Media Systems</b>	J-1500	1500

The technologies listed in this permit are used to treat low-strength effluent to discharge to a soil-based wastewater disposal system. The technologies, consisting of an aerobic, fixed film media treatment of wastewater, are hereby approved under the requirements of the regulations named above subject to the following conditions.

**1. GENERAL**

- 1.1 The technologies listed in this permit may be used as part of a soil-based wastewater system permitted under the Rules provided the conditions of this permit are met.
- 1.2 Failure by the Permittee to comply with these conditions is grounds for the Secretary to revoke or not renew the Approval Permit.
- 1.3 The approval shall expire on **May 1, 2023**. Applications for renewal of this Approval Permit shall be submitted to the Division by March 1, 2023, to avoid a lapse in approval. The renewal request shall be submitted on a form prepared by the Secretary and shall include: a description of any changes to the equipment, technical specifications and drawings, installation requirements, and operation and maintenance manuals.
- 1.4 No changes shall be made to the approved technology without prior review and approval by the Secretary.
- 1.5 This Approval Permit is based on the design, operation, and maintenance manuals submitted by the Permittee to the Secretary. Misrepresentation in the application material is grounds for the Secretary to revoke this permit.
- 1.6 If the Rules are revised during the term of this Approval Permit, this permit shall be revised as needed to conform to the revisions.
- 1.7 Site-specific permission for the use of this technology is required in the form of a Wastewater System and Potable Water Supply Permit (WW Permit).



- 1.8 This permit is not a representation or guarantee of the effectiveness, efficiency, or operation of the approved technology.
- 1.9 This General Use Approval Permit is limited to treating septic tank effluent that is characterized as low strength according to §1-805(b) of the Rules.
- 1.10 This approval is based on information submitted by the Permittee indicating that the technology will treat the effluent to reduce the biochemical oxygen demand (BOD<sub>5</sub>) to 30 mg/L or less and total suspended solids (TSS) to 30 mg/L or less.
- 1.11 Each Vermont landowner in interest shall be shown a copy of the Wastewater System and Potable Water Supply Innovative and Alternative System General Use Approval Permit, the Operation and Maintenance manuals, and projected maintenance costs prior to the installation of any permitted unit.
- 1.12 All components of the technology shall be warranted for the first 2 years following commencement of use of technology unit. The permittee shall have an inventory of replacement parts available locally or available for delivery within 24 hours.
- 1.13 All conditions set forth in WW Permits that include the use of the approved technology shall remain in effect and may surpass the conditions set herein.
- 1.14 A WW Permit that approves the use of a technology approved by this permit remains valid for the use of the technology identified in the WW Permit even if this permit expires.

## 2. DOCUMENTS

- 2.1 The approval of the I/A technology is based on the following documents submitted by the permittee:

Title	Submission Date	Revision
V-ANR Innovative and Alternative Technology Renewal Application	03/15/2021	None

- 2.2 Use of the I/A technology in ways not depicted or described in the documents, and or identified in this permit, is not allowed without prior approval by the Drinking Water and Groundwater Protection Division.

## 3. SERVICE PROVIDER

- 3.1 The Permittee shall contract with and maintain a minimum of two Service Providers for the State of Vermont (Vermont Service Provider) to perform the inspections, maintenance, and repairs required by this permit and by conditions of the WW Permit. The Vermont Service Providers must be based in Vermont or in a neighboring state or province and be ready and willing to provide service to the technologies in Vermont.
- 3.2 The Permittee shall provide to the Secretary the names, mailing addresses, email addresses, and phone numbers of two or more service providers prior to the Division issuing a WW Permit for use of the technology.
- 3.3 The Permittee shall maintain with the Secretary the names and contact information for all Vermont Service Providers. The Permittee shall notify the Secretary within 30 days of termination of an existing and/or hiring of a new Service Provider. Failure to maintain a minimum of two Vermont Service Providers will result in the Secretary prohibiting the issuance of a WW Permit with the approved technology.
- 3.4 The Permittee shall provide training to each Vermont Service Provider for the proper operation, maintenance, and repair of each approved technology.
- 3.5 Service Providers must follow Permittee and WW Permit conditions for inspection, maintenance, and reporting requirements.

- 3.6 Maintenance and inspections of the approved technology must be performed by a Service Provider trained and authorized by the Permittee. Reports shall be provided to the Permittee, landowner, and Division in a timely manner so that they can ensure conditions of the WW Permits are met.
- 3.7 Maintenance and inspections performed by Service Providers shall be in accordance with the operation and maintenance manual submitted as part of the I/A permit approval application, as provided in trainings by the Permittee, and specified in the WW Permits issued by this Division.

#### 4. REPORTS

- 4.1 The Permittee shall submit electronically by April 1<sup>st</sup> of each year an annual report to the Division containing the following information for the previous 12-month period ending December 31<sup>st</sup>:
  - A. the entities who are distributing the permitted technology in the State of Vermont
  - B. a listing of each permitted technology installed in Vermont during the previous calendar year with the following information:
    - i. assigned WW Permit number;
    - ii. the property's SPAN number;
    - iii. the distributor who sold the installed technology
    - iv. the name of the Vermont-licensed Designer providing the installation certification;
    - v. the name of the contracted and authorized Service Provider inspecting the technology at the time of installation;
    - vi. the date installed, and;
    - vii. the date of initial use of the technology (beginning of 2-year warrantee period).
- 4.2 The Permittee shall ensure the Vermont Service Providers for each of the permitted systems utilizing this technology installed in Vermont are submitting to the Division the following reports;
  - A. an initial report of an inspection conducted within 60 days of initial usage;
  - B. inspection reports of the I/A technology conducted every 6 months for the first two years of usage;
  - C. inspection reports of the I/A technology conducted annually following the initial two years of usage.
- 4.3 Maintenance and inspections reports shall be submitted on the Secretary-approved inspection report form and be signed and dated by the Service Provider.
- 4.4 Inspection reports by the Service Provider shall include but not be limited to a summary of all known problems, damages, and/or failures of the technology to comply with this approval and operating requirements for the technology, including:
  - A. a description of any problems, damages, and/or failures;
  - B. potential/known causes of any problems, damages, and/or failures;
  - C. a statement of system operability including whether or not the technology is operating in compliance with this approval and operating specifications following repairs or corrections of any problems, damages, and/or failures;
  - D. a listing of the required repair/remediation;
  - E. identification of changes to the technology specifications; and
  - F. any observed failure of the wastewater system including wastewater exposed to the open air, wastewater pooling on the surface of the ground, wastewater discharging directly to surface water, or wastewater backing up into the building or structure.
- 4.4 Problems, damages, and/or failures of the technology identified during an inspection per condition 4.3 of this permit must be reported by the service provider immediately to the landowner and within 30 days to the Division.

4.5 Maintenance and inspections shall be performed in accordance with the permitted operation and maintenance manual that are specified in the WW Permits issued by this Division.

## 5. DESIGN SPECIFICATIONS

5.1 The design of a wastewater system using the approved technology shall identify the specific approved -model and shall not be replaced with any other model without an amendment to the WW Permit.

5.1 Technologies shall be equipped with anti-flotation devices. The Permittee may specify whether or not the anti-flotation device are required if a designer demonstrates flotation will not occur or the designer proposes in an application for the use of the technology an alternative method to stabilize the technology that complies with the Permittee's requirements for installation.

5.3 Technology model choice and sizing shall be in accord with the Permittee's technical requirements approved by the Secretary. Sizing of each unit shall be based on the calculated design flow per §1-803 of the Rules.

## 6. INSTALLATION SPECIFICATIONS

6.1 The approved technology shall be installed under the guidance of a Service Provider and a designer.

6.2 The installation of each technology shall be in accordance with the Permittee's technical requirements approved by the Secretary.

6.3 All installations must have a valid WW Permit specifying the make and model, prior to the unit being installed. Any reports of unpermitted installations will be grounds for revocation of this approval permit.

Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

Peter Walke, Commissioner  
Department of Environmental Conservation

By 

Dated May 20, 2021

Cristin Ashmankas, Environmental Analyst VI  
Regional Office Program  
Drinking Water and Groundwater Protection Division





Department of Environmental Conservation  
Wastewater System & Potable Water Supply Permit Application

**ANR Form 4: Certification Statement for Notification of Overshadowed Property Owners  
Pursuant to the Wastewater System & Potable Water Supply Program**

A person submitting an application to the Secretary for a Wastewater System and Potable Water Supply Permit where the proposed project has isolation distances (overshadowing) that extend onto property owned by persons other than the permit applicant shall submit the following certification with the application.

**Note:** When the property subject to the permit application is owned by more than one person, only one of the landowners must sign this certification statement even though all landowners must sign the permit application itself.

*I hereby certify that the individual(s) that own property that is overshadowed by my proposed project have been sent by certified mail a copy of the required notification form and the site plan(s) that accurately depicts all isolation distances. I also certify that I attached to this certification form a copy of all certified mail receipts for notifications that were sent to the affected property owners.*



Landowner Signature

Eric S. Eklof, Jr. or Irma Eklof

Print Landowner Name

7-21-2021

Certification Date

2 Deer Crossing Lane, Essex Jct., VT

Property Address or Property Tax ID#

Please list all of the property owners who were sent a notification by certified mail. Use additional sheets if necessary. If additional sheets are required, each sheet must be signed by the Landowner.

Stephani & Andrew Cookingham

Property Owner Name

2 Whitetail Lane Essex Jct., VT 05452

Property Owner Address

Property Owner Name

Property Owner Address

Department of Environmental Conservation

**Wastewater System & Potable Water Supply**

# Installation Certification Signature Sheet

**Instructions:**

 The Submission Number and Version of the online Installation Certification being signed **must** be entered in the field below.

**Hand Signatures** - This signature sheet can be downloaded, printed, signed by hand, and then scanned and uploaded to the **Signatures** section of the online form.

**Digital Signatures** - This signature sheet can be signed using the certificate-based digital signature capability available in Adobe Acrobat/Reader (or other PDF software with similar capability) and then uploaded to the **Signatures** section of the online application form. If this sheet contains one or more digital signatures, it **must** be uploaded in a format that does not compromise the ability to click on the applied signature and validate it. The digital signature applied must include the signer's full name, email address, and the date and time of signing. Because the Signature Sheet needs to be submitted in a format that allows the signatures to be validated, a Signature Sheet cannot contain both digital and hand signatures.

**Note:** If you digitally sign this sheet, please don't enter a date in the Signature Date field. The date and time must be included in the digital signature that is applied as described above.

**ANR Online Submission Number & Version**

ANR Online Submission Number and Version (for example: #20J-65KQ-R1ZF, version 1)

HPD-7NHN-G1N77

**Permit and Lot Number**

Permit Number and Lot Number, if applicable

WW-4-5622

Select the type of installation(s) being certified on this ANR Online Submission:

- |  |   |
|--|---|
| <input checked="" type="radio"/> Wastewater System               | <input type="radio"/> Water Supply                            |
| <input type="radio"/> Wastewater System Requiring Record Drawing | <input type="radio"/> Water Supply Requiring Record Drawing   |
| <input type="radio"/> No Wastewater System Installation          | <input checked="" type="radio"/> No Water Supply Installation |

Insert Certification Language

**Check the appropriate installations above and click the 'Insert Certification Language' button to include the appropriate verification text.**

I hereby certify that, in the exercise of my reasonable professional judgement, the installation-related information submitted is true and correct and that the wastewater system was installed in accordance with the permitted design and all the permit conditions, was inspected, was properly tested, and has successfully met those performance tests.

**Designer(s)/Installer(s) Certification**

WW Designer

Designer/Installer Role

Justin T. Willis

Print Designer/Installer Name

Justin T. Willis

Designer/Installer Signature

 Digitally signed by Justin T. Willis  
Date: 2021.11.14 15:26:22 -05'00'

Signature Date

Designer/Installer Role

Print Designer/Installer Name

Designer/Installer Signature

Signature Date

**Town Record Filing Information**

If using this form to provide the Town with certification information for filing in land records, fill out the appropriate/available information below. Other Identifiers might include SPAN, Landowner name(s), 911 Address, etc.

Parcel ID

2105107008

Town Clerk may indicate receipt here

Subdivision Name/Lot #

Other Identifier(s)

Other Identifier(s)