

Sharon Kelley

From: Dennis Lutz
Sent: Thursday, March 19, 2015 2:35 PM
To: Sharon Kelley; Aaron Martin
Subject: RE: GMCR 30 Gauthier Drive

No issues re Public Works

From: Sharon Kelley
Sent: Thursday, March 19, 2015 2:18 PM
To: Aaron Martin
Cc: Dennis Lutz; Sharon Kelley
Subject: GMCR 30 Gauthier Drive

Aaron,

GMCR has submitted a building permit with the Town and State for interior remodeling. See attached plans and narrative below.

"The following describes the project at Keurig Green Mountain/Essex Plant which we are applying for a permit.

Enclose (1) product packaging fill line (PL124) with a 44' x 45' x 17' high room for the purpose of controlling temperature and humidity.

The room is constructed with interlocking metal panels and sits on the existing concrete floor. The room has (8) windows, (2) man doors and (1) roll up product door.

The project includes a new dehumidification unit located on an existing equipment mezzanine and an exhaust fan to keep the room negative.

Distribution ductwork delivers conditioned air to the room through ceiling diffusers and return grilles.

The room has new lighting designed for 50 foot candles and fire protection horn & strobe off the house fire alarm system.

The new space is protected with sprinkler heads piped off the house sprinkler system.

This project is completely inside of the existing KGM Building #1 (Gauthier Building) and has no impact on the existing building size or configuration."

Will any of these modifications require conditions from Public Works? If so, I may require a minor amendment with the Planning Commission. I will question them on the noise factor and confirm that it will be internal noise...

Thanks.

SK

Sharon L. Kelley, Zoning Administrator
Town of Essex, 81 Main Street
Essex Jct., VT 05452
(802) 878-1343
skelley@essex.org