

Indian Brook Water Test Results:

The water at Indian Brook is tested every two weeks through the Vt Department of Health. The Parks & Recreation Department tests the water in three different locations. The locations are identified on the map. The Department of Health has identified the acceptable level of E-coli at 77 parts/100ml for swimming. The test results from the three locations are posted below.

Tested Date Tested Site Results

past results:

08-28-2007	1	14 E.coli / 100 ml
08-28-2007	2	4 E.coli / 100 ml
08-28-2007	3	3 E.coli / 100 ml
08-15-2007	1	5 E.coli / 100 ml
08-15-2007	2	9 E.coli / 100 ml
08-15-2007	3	14 E.coli / 100 ml
07-30-2007	1	4 E.coli / 100 ml
07-30-2007	2	3 E.coli / 100 ml
07-30-2007	3	2 E.coli / 100 ml
07-17-2007	1	3 E.coli / 100 ml
07-17-2007	2	15 E.coli / 100 ml
07-17-2007	3	4 E.coli / 100 ml
07-02-2007	1	< 77 E.coli / 100 ml
07-02-2007	2	< 77 E.coli / 100 ml
07-02-2007	3	< 77 E.coli / 100 ml
06-19-2007	1	27 E.coli / 100 ml
06-19-2007	2	18 E.coli / 100 ml
06-19-2007	3	11 E.coli / 100 ml