

Indian Brook Water Test Results:

The water at Indian Brook is tested every two weeks through the Vt Department of Health. The Parks & Recreation Department tests the water in three different locations. The locations are identified on the map. The Department of Health has identified the acceptable level of E-coli at 77 parts/100ml for swimming. The test results from the three locations are posted below.

<u>Tested Date</u>		<u>Tested Site Results</u>
09-01-2009	1	1 E.coli / 100 ml
09-01-2009	2	0 E.coli / 100 ml
09-01-2009	3	0 E.coli / 100 ml
08-19-2009	1	0 E.coli / 100 ml
08-19-2009	2	1 E.coli / 100 ml
08-19-2009	3	0 E.coli / 100 ml
08-03-2009	1	25 E.coli / 100 ml
08-03-2009	2	34 E.coli / 100 ml
08-03-2009	3	95 E.coli / 100 ml
07-22-2009	1	6 E.coli / 100 ml
07-22-2009	2	1 E.coli / 100 ml
07-22-2009	3	25 E.coli / 100 ml
06-15-2009	1	19 E.coli / 100 ml
06-15-2009	2	4 E.coli / 100 ml
06-15-2009	3	4 E.coli / 100 ml