

TOWN OF ESSEX

APPLICATION FOR CERTIFICATE OF OCCUPANCY

No. 1753-86

April 30 19 87

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

This request is for use only of existing land or buildings.

This request is for new construction or rehabilitated or altered structure which was done under authority of building/zoning permit # 1753-86

issued Aug 26 19 86 to Jack Valle  
(NAME)

Premises are at Old Pump Rd, Essex, Vt. [Valle property, access from Sherry Fox]  
(STREET ADDRESS)

Applicants Mailing Address (If different) RD 2 Box 591, Underhill, Vt. 05489

Driveway location inspected and approved by Dennis Lutz

Water service installation inspected and approved by \_\_\_\_\_  
Tested for purity - passed - will bring statement (NAME)

Sanitary sewer connection or septic system inspected and approved by:

Don Marsh [Dufresne-Henry]\* \_\_\_\_\_ 19 \_\_\_\_\_  
(NAME) Montpelier (DATE)  
*\* Letter was sent to Mr. Ferkey*

Construction was begun Dec 1 19 86 and completed April 29 19 87

Actual cost of construction \$ ~~180,000~~ inc. sitework

Approval granted by \_\_\_\_\_ Planning Commission \_\_\_\_\_ Zoning Board of Adjustment  
\_\_\_\_\_ 19 \_\_\_\_\_.

Use of premises intended Single Family Residence  
(What will you use the new bldg., addition or alt. for)

Daytime phone # 899-3077 4/30 19 87  
(DATE)

Brian Vorse  
(APPLICANT'S SIGNATURE)

Certificate of Occupancy approved  with \_\_\_\_\_ without  conditions.

Certificate of Occupancy denied \_\_\_\_\_. Please see attachment with reasons for denial.

April 30 19 87  
(DATE)

Jay Z. Pirbey  
Zoning Administrator  
Town of Essex, Vermont

# DH Dufresne-Henry

Dufresne-Henry, Inc.  
58 East State Street  
Montpelier, Vermont 05602  
802-229-0711

**Engineering Disciplines**  
Civil  
Environmental  
Transportation  
Municipal  
Mountain  
Structural  
Electrical  
Mechanical  
Industrial

**Associated Disciplines**  
Surveying  
Construction Management  
**Applied Sciences**  
Water Quality  
Geologic  
Hydrologic  
Computer

February 9, 1986

Mr. Jerry Ferkey  
Town of Essex  
Essex, Vermont 05451

re: Mound system on lot owned by Jack Valley, Pump Road, Essex


Dear Mr. Ferkey:

The wastewater disposal system designed by Marshfield Engineering was constructed in the location specified in the engineering plans. A sample of the mound sand was approved for use by Don Marsh. The sand present on site and used for the system appeared to be the same sand. There was evidence around the periphery of the mound that the surface had been plowed before placement.

The pressure distribution system was inspected and was placed properly. A test run of the siphon indicated that the flow throughout the distribution pipe was uniform. The final cover for the system was not inspected until after snowfall. However, the dimensions of the mound were correct and native grasses were uncovered at the toe of the mound indicating this area had not been disturbed during construction.

This wastewater disposal system appears to have been constructed according to the plans and specifications provided by Marshfield Engineering (now part of Dufresne-Henry).

Very truly yours,

  
Nancy J. Hoelper  
Project Engineer

NJH/fc

cc: Brian Vorse