

### **Indian Brook Water Test Results 2011:**

The water at Indian Brook is tested every two weeks through the Vt Department of Health. The Parks & Recreation Department tests the water in three different locations. The locations are identified on the map. The Department of Health has identified the acceptable level of E-coli at 77 parts/100ml for swimming. The test results from the three locations are posted below.

<u>Tested Date</u>	<u>Tested Site</u>	<u>Results</u>
08-23-2011	1	6 E.coli / 100 ml
08-23-2011	2	1 E.coli / 100 ml
08-23-2011	3	2 E.coli / 100 ml
08-11-2011	1	< 77 E.coli / 100 ml
08-11-2011	2	< 77 E.coli / 100 ml
08-11-2011	3	< 77 E.coli / 100 ml
07-20-2011	1	66 E.coli / 100 ml
07-20-2011	2	4 E.coli / 100 ml
07-20-2011	3	3 E.coli / 100 ml
07-06-2011	1	50 E.coli / 100 ml
07-06-2011	2	53 E.coli / 100 ml
07-06-2011	3	10 E.coli / 100 ml
06-15-2011	1	2 E.coli / 100 ml
06-15-2011	2	4 E.coli / 100 ml
06-15-2011	3	1 E.coli / 100 ml