

Indian Brook Water Test Results 2012:

The water at Indian Brook is tested every two weeks through the Vt Department of Health. The Parks & Recreation Department tests the water in three different locations. The locations are identified on the map. The Department of Health has identified the acceptable level of E-coli at 77 parts/100ml for swimming. The test results from the three locations are posted below.

<u>Tested Date</u>	<u>Tested Site</u>	<u>Results</u>
08-21-2012	1	2 E.coli / 100 ml
08-21-2012	2	0 E.coli / 100 ml
08-21-2012	3	2 E.coli / 100 ml
08-06-2012	1	9 E.coli / 100 ml
08-06-2012	2	20 E.coli / 100 ml
08-06-2012	3	29 E.coli / 100 ml
07-23-2012	1	1 E.coli / 100 ml
07-23-2012	2	3 E.coli / 100 ml
07-23-2012	3	1 E.coli / 100 ml
07-11-2012	1	4 E.coli / 100 ml
07-11-2012	2	2 E.coli / 100 ml
07-11-2012	3	3 E.coli / 100 ml