

Eric Martin

APPLICATION FOR CERTIFICATE OF OCCUPANCY

NO. 202-94 3/13, 1995

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

- This request is for use only of existing land or buildings.
- This request is for new construction or rehabilitated or altered structure which was done under authority of building/zoning permit # 202-94

issued 9-26-94, 1994 to 10-12-94

Premises are at 72 Osgood Hill Rd

Water service installation inspected and approved by private well

Driveway location inspected and approved by Dennis Lutz

Sanitary sewer connection or septic system inspected and approved by:

Name: JH Stuart Date: MAR 9, 1995

Construction was begun Nov 20, 1994 and completed MAR 14, 1995

Approval granted by: P.C. Z.B.A., 19 .

Use of premises intended SINGLE FAMILY HOUSES
(type of use)

Applicant's Signature: [Signature] Consulate Const. Inc.

By issuance of this Occupancy Permit, the Town of Essex Zoning Administrator hereby acknowledges that the use and/or building construction is in complete conformity with the Zoning Regulations, unless otherwise noted. Field measurements and similar dimensions for setbacks are based in part on evidence supplied by owner. The Town of Essex is not liable for errors or mistakes when it is found that information submitted by the applicant is erroneous or inaccurate.

Certificate of Occupancy approved with without conditions
If with conditions, see attachment outlining same.

Certificate of Occupancy denied . Please see attachment with reasons for denial.

Date 3-13-95 [Signature]
Zoning Administrator, Town of Essex, VT

JHSTUART

March 9, 1995

Cloverdale Construction
Attn: Eric Martin
RR1 Box 6785
Underhill, Vermont 05489

Re: Krausse Residence

Dear Eric:


Please be advised that I performed a final inspection of the mound system constructed at the above property located on Osgood Hill Road.

Whereas the majority of construction occurred last fall, the inspection was limited to performing a pressure distribution test on this date. A dosing tank had been substituted for the pump station and the resultant pressure was a uniform 45 inches throughout the field. After the snow leaves and the surface is dry, the final grading, topsoil and seed can be applied.

I noted that snow machine tracks crossed the field in several locations. Please advise the owner that there is not to be any vehicular traffic allowed on the mound as the system can be damaged by the weight. Hopefully, the passes over the field have not caused any serious problems.

Based on my inspection today, the system is considered acceptable for activation. Feel free to contact me if you have any questions or comments.

Regards,



John H. Stuart, P.E.

JHS/gate

cc: RMB Construction