

TOWN OF ESSEX CERTIFICATE OF OCCUPANCY APPLICATION

DATE OF REQUEST: 10/14/05

MAP/PARCEL/LOT: _____

NO. 2005-132

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

This request is for use only of existing land or buildings.

This request is for new construction or rehabilitated or altered structure which was done under authority of zoning permit # 2005-132

issued to Kittel Builders on 6-1-05

Premises are at 22A Foster Rd unit, A

Water service installation inspected and approved by TOE Hamlin Engineers

Driveway location inspected and approved by TOE Hamlin Engineers

Sanitary sewer connection or septic system inspected and approved by:

Name: Steve Lilewski, H.E. Date: Aug 28 2005

Construction was begun JULY, 2005 and completed OCT, 2005

Approval granted by P.C. or Z.B.A. on PC-2005-9
213A 2005-1, 2005.

Use of premises intended Condominium - 2 Bedrooms
(type of use)

Applicant's Signature: [Signature] Telephone: 343-3534
879-0458

Otherwise noted: All measurements and dimensions for subjects are taken by applicant or person supplied by owner. The Town of Essex is not liable for errors or mistakes when it is found that information submitted by the applicant is erroneous or inaccurate.

Certificate of Occupancy has been approved with _____ without conditions.
If with conditions, see attachment outlining same.

Certificate of Occupancy denied _____. Please see attachment with reasons for denial.

10/18/05
Date [Signature]
Jerry L. Firkey, Zoning Administrator

FIRE PREVENTION INSPECTION RESULTS

Vermont Department of
Public Safety
Division of Fire Safety

- Central Office • Phone (802) 479-7561
- Williston, VT • Phone (802) 879-2300
- Barre, VT • Phone (802) 479-4434
- Rutland, VT • Phone (802) 786-5807
- Springfield, VT • Phone (802) 885-8883

Site Number: 72921

Buildings name and address: Foster Road Town Homes
22 Foster Road, Essex, Vt.

Owner's name and address: _____

Occupancy by floor: _____ Risk Index: _____

No. of occupants: _____ 901

Violations: This is a final inspection for all
3 dwellings. The Unit numbers must be
posted by each entrance.

The basements are currently un-finished
and will require additional permits if used
for anything other than storage purposes.
Nothing is to be hung (clothes, hanging carpets,
etc.) from the gas piping.

* Occupancy and use of all 3 dwellings is Granted;

Inspection Date: 13 Oct 05 Type: Final Hazard Index: 1 2 3 4 5

Compliance with all regulations must be achieved by: 11/1/05

Occupancy Granted: Yes * No _____

Referred to: _____

Person accompanying Assistant Fire Marshal: Chris Kittell

Chris G. Kittell
Assistant Fire Marshal

CC: