

# TOWN OF ESSEX CERTIFICATE OF OCCUPANCY APPLICATION

DATE OF REQUEST: 4/23/07 FEE: \$82.00 PL SK (includes recording)  
MAP/PARCEL/LOT: 091/006/000 NO. 2007-20

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

- This request is for use only of existing land or buildings.
- This request is for new construction or rehabilitated or altered structure which was done under authority of zoning permit # 2007-20

issued to Summerville LLC on 3/16/07

Premises are at 8 Essex Way Lower Level East

Water service installation inspected and approved by N/A public

Driveway location inspected and approved by N/A preexisting

Sanitary sewer connection or septic system inspected and approved by:

Name: N/A - public - preexisting Date: \_\_\_\_\_

Construction was begun March 16, 20 07 and completed 4/23, 20 07

Approval granted by \_\_\_\_\_ P.C. or Z.B.A. on \_\_\_\_\_, 20 \_\_\_\_.

Use of premises intended office space  
(type of use)

Applicant's Signature: [Signature] Telephone: 8791233 Cell: 800 9340994

By issuance of this Occupancy Permit, the Town of Essex Zoning Administrator hereby acknowledges that the use and/or building construction is in complete conformity with the Zoning Regulations, unless otherwise noted. Field measurements and similar dimensions for setbacks are based in part on evidence supplied by owner. The Town of Essex is not liable for errors or mistakes when it is found that information submitted by the applicant is erroneous or inaccurate.

Certificate of Occupancy has been approved with \_\_\_\_\_ without  conditions.  
If with conditions, see attachment outlining same.

Certificate of Occupancy denied \_\_\_\_\_. Please see attachment with reasons for denial.

1107  
Sharon L. Kelley  
Acting Zoning Administrator

FIRE PREVENTION INSPECTION RESULTS

Vermont Department of  
Public Safety  
Division of Fire Safety

- Central Office - Ph. (802) 479-7561
- Williston, VT - Ph. (802) 879-2300
- Barre, VT - Ph. (802) 479-4434
- Rutland, VT - Ph. (802) 786-5867
- Springfield, VT - Ph. (802) 885-8883

Site Number: 29929

Buildings name and address: 8 Essex Way, Essex  
Essex Union Annex, Basement

Owner's name and address: John Sumner  
Professional office

Occupancy by floor: Basement Risk Index: \_\_\_\_\_

No. of occupants: \_\_\_\_\_ 901 \_\_\_\_\_

Violations: 1. New Firearm Area must have penetration  
filled with mineral wool or Fire Calked

Inspection Date: 4-23-07 Type: Final Hazard Index: 1 2 3 4 5

Compliance with all regulations must be achieved by: May 23, 2007

Occupancy Granted: Yes  No

Referred to: \_\_\_\_\_

Person accompanying Assistant Fire Marshal: A. McHale Gerry, Joe

Gary Palmer  
Assistant Fire Marshal

cc:

Revised 12/13/05