

878 1253

TOWN OF ESSEX CERTIFICATE OF OCCUPANCY APPLICATION

DATE OF REQUEST: 9/10/09 FEE: \$85.00 PK (includes recording)

MAP/PARCEL/LOT: 72 3-1 2078003001 NO. 2009-21

The undersigned herewith requests an inspection of the premises and the issuance of "Certificate of Occupancy" of premises, or portion thereof, for use or habitation.

This request is for use only of existing land or buildings.

This request is for new construction or rehabilitated or altered structure which was done under authority of zoning permit # 2009-21

issued to (Matthew Stevens) Energy Services d/b/a Stevensbas on 4/9/09

Premises are at 189 Colchester Rd., Essex Jct., VT 05452

Water service installation inspected and approved by N/A

Driveway location inspected and approved by N/A

Sanitary sewer connection or septic system inspected and approved by: N/A

Name: _____ Date: _____

Construction was begun May, 2009 and completed June, 2009

Approval granted by _____ P.C. or Z.B.A. _____ on _____, 20____.

Use of premises intended _____
(type of use)

Applicant's Signature: Richard R. Wheelock Telephone: 802/878/370 Cell: 802/238-7072

By issuance of this Occupancy Permit, the Town of Essex Zoning Administrator hereby acknowledges that the use and/or building construction is in complete conformity with the Zoning Regulations, unless otherwise noted. Field measurements and similar dimensions for setbacks are based in part on evidence supplied by owner. The Town of Essex is not liable for errors or mistakes when it is found that information submitted by the applicant is erroneous or inaccurate.

Certificate of Occupancy has been approved with _____ without conditions.
If with conditions, see attachment outlining same.

Certificate of Occupancy denied _____. Please see attachment with reasons for denial.

9-15-09
Date

Sharon L. Kelley
Zoning Administrator



VERMONT DEPARTMENT OF PUBLIC SAFETY
DIVISION OF FIRE SAFETY
Electrical & Fire Alarm Work Notice

Department Use Only

Site No. _____
EWN# RM-2407
Date Paid 7/2/2009
Check # 401-3035
Amount 40.00

Return this application to the appropriate Regional Office:
1311 US Route 302-Berlin, Suite 500, Barre, VT 05641-7301; Phone: 802-479-4434
56 Howe Street, Building A, Suite 200, Rutland, VT 05701; Phone: 802-786-5867
100 Mineral Street, Suite 307, Springfield, VT 05156-3168; Phone: 802-885-8883
372 Hurricane Lane, Suite 102, Williston, VT 05495-2080; Phone: 802-879-2300
Office of the State Fire Marshal & Fire Academy - www.vtfiresafety.org

SEP 10 2009
COMMUNITY DEV. OFFICE

LOCATION INFORMATION

Name of Building/Site: STEVENS GAS
Physical Location: RT 2 A ESSEX JCT VT 05452
(9-1-1 Address) *Number and street name, city/town, zip code*
Name of Lessee: STEVENS GAS
(if business)
Building Owner Name: ENERGY CORP
Owner Mailing Address: _____
Number and street name or PO Box, city/town, zip code
Owner Phone #: _____
Explain the use of the building: PROpane FILLING If residential, number of units: _____
Provide a description of the work: BRANCH CIRCUIT FOR GATE OPENER
Job Start Date: 07-02-09 Projected Finish Date: 07-09-09

RECEIVED

JUL 02 2009

DIVISION OF FIRE SAFETY
WILLISTON OFFICE

ELECTRICIAN INFORMATION

Name of Electrician: RICK CUSSON JR License Number: EM-8042
Name of Company: R. C Electric License Expiration Date: 05/12/11
Mailing Address: 644 RIX RD South Royalton VT 05068
Number and street name or PO Box, city/town, zip code
Electrician Contact Number(s): 283-3698 Electrician's Signature: Richard A Cusson

FIXTURES	FEE	QUANTITY	AMT DUE
Temporary Service	\$30.00 ea	X	
Permanent Service (1 & 2 Phase through 400 amp)	\$35.00 ea	X	
Permanent Service (401 amp through 800 amp)	\$50.00 ea	X	
Permanent Service (801 amp and larger)	\$100.00 ea	X	
Transformers, 1 - 25 KVA	\$10.00 ea	X	
Transformers, 26 - 75 KVA	\$15.00 ea	X	
Transformers, 76 - 200 KVA	\$25.00 ea	X	
Transformers, over 200 KVA	\$35.00 ea	X	
Motors and Generators, Up to 25 hp, KW, or KVA	\$10.00 ea	X	1 10.00
Motors and Generators, 26 - 100 hp, KW, or KVA	\$15.00 ea	X	
Motors and Generators, over 100 hp, KW, KVA	\$25.00 ea	X	
Sub Panels and Feeder after the main disconnect	\$10.00 ea	X	
Lights, Outlets, Switches, Single-Station Smoke Detectors	\$20.00 per 50	X	
Yard Lights and Signs	\$5.00 ea	X	
Fuel Oil, Kerosene, LP, NG, and Gasoline Pumps	\$15.00 ea	X	
Boiler, Furnace, Control Device & Stationary Appliances	\$10.00 ea	X	
Elevators	\$75.00 ea	X	
Platform Lifts	\$40.00 ea	X	
Fire Alarm Devices	\$30.00 per 50	X	
Fire Alarm Main Panel and Annunciator Panels	\$50.00 ea	X	
Fire Pumps	\$50.00 ea	X	
Base Fee, Except for 1 & 2 Family Residential Dwellings	\$30.00 ea	X	1 30.00
TOTAL FEE			40.00

The fees assessed for electrical and fire alarm work notices are set forth in the "State of Vermont Electrical Safety Rules", pursuant to 26 V.S.A. § 893(a).
There is a minimum fee of \$35.00 for each re-inspection for code violations.
This application must be filled out completely. Incomplete forms will not be processed.
A separate work notice must be filed for each building.
Payment must be included at the time of submission.
Fire Alarm installation requires a plan review submittal, construction permit application and fee, prior to installation.

Rod Wheelock

RECEIVED

From: jbenard@dps.state.vt.us
Sent: Tuesday, June 30, 2009 12:58 PM
To: Rod Wheelock
Cc: jbenard@dps.state.vt.us
Subject: rpt372 06/30/2009

SEP 10 2009
cc

06/30/09 12:58

SITE 32996
EVENT 1250735

STATE OF VERMONT
DEPARTMENT OF PUBLIC SAFETY
BUILDING INSPECTION REPORT

Site Details:

STEVENS GAS SUPPLY
189 COLCHESTER ROAD
ESSEX JCT VT 05452

Date of Inspection:
06/30/09

Compliance Date:
07/30/09

Owned By:

Achieved Date:
//**

Inspected By:
BENARD

Inspection Type:
OCCUPANCY Description of

Project: TANK 2008
Hazard Index: 2
Violations: NONE ENTERED

Notes/Details:

THE FIRE ALARM AND SPRINKLER SYSTEM ISSUES HAVE BEEN COMPLETED.
YOU HAVE 30 DAYS ON THE REMOVAL OF THE FUEL TANKS
OKAY TO FILL AND USE NEW 30,000 GALLON LP TANK